

Question:	How many devices can I install in a Wireless system?
Answer:	The system allows the configuration of a maximum of 64 devices for each gateway code 14597-16497-19597-20597
Question:	Which App is dedicated to system configuration?
Answer:	The system can be configured using the View Wireless App.
Question:	How do you reset the devices?
Answer:	Resetting is done by pressing the configuration push button for a prolonged amount of time, which must be done within 5 min of commissioning (powering) the product.
Question:	Which function envisages the actuator device art.14593-19593-20593-16593, configured in energy monitoring mode?
Answer:	The product allows the display of the energy consumed and the disconnection upon exceeding a given threshold which can be set by the user.
Question:	How many Energy meters art.02963 can I install in a Wireless system?
Answer:	Each connected system allows a maximum of 2 meters art.02963.
Question:	Can the connected 2-way switch art.14592-19492-19592-20592 be used as a 1-way switch for a controlled socket outlet
Answer:	No, as a minimum load of 2W is necessary for correct operation. To manage a controlled socket outlet, you can use art. 14593-16493-19593-20593 or art. 03981
Question:	Can products 14593 and 14592 be used as light dimmers?
Answer:	No, these devices cannot be used in the dimmer function.